

User input indicated by **Orange fields**

User Input	
Zoning lookup	Minimum GI Score
REGEN	0.5

1. Enter Development Site Area m <sup>2</sup> <b>HERE</b> ▶		13277	
Surface Type (see tab for detailed descriptions)	Factor	Proposed Surface Area m <sup>2</sup>	Factor Values
1. Short Lawn	0.3	1654	496.2
2. Tall Lawn (wild, not mown)	0.5	873	436.5
Permeable Paving	0.3	2790	837
Vegetation			0
4a. Vegetation-Shrub below 3m	0.4	500	200
4b. Vegetation-Shrub / Hedgerow above 3m	0.5		0
4c. Vegetation-Pollinator friendly perennial planting	0.5	1924	962
4d. Vegetation-Preserved hedgerow	1.2		0
Trees			0
5a. New trees	0.6	660	396
5b. Preserved trees	1.2	39	46.8
7. SuDS intervention (rain garden, bioswale)	0.6	2635	1581
Green Roof			0
9a. Green Roofs - Intensive green roof (substrate is 200-1200mm in depth)	0.7	782	547.4
9b. Green Roofs - Extensive green roof (substrate is 80-200mm in depth)	0.6	2288	1372.8
10. Green wall	0.4	0	0
11. Retained Open Water	2	0	0
12. New open water	1.5	0	0
<b>Total Equivalent Surface Area of Greening Factors</b>		<b>14,145.00</b>	

<b>Green Factor Numerator</b>	<b>6875.70</b>
-------------------------------	----------------

Minumum Required GI score	Final GI score	Result
0.5	0.52	Pass